

**61-30.803 Standards of Practice, Electrical Systems.**

- (1) Electrical systems and components include the following:
  - (a) Service entrance conductors, drip loop, cables, and raceways;
  - (b) Main service equipment and main disconnects;
  - (c) Service grounding;
  - (d) Interior components of main service panels and sub panels;
  - (e) Conductors;
  - (f) Over current protection devices;
  - (g) Readily accessible installed lighting fixtures, switches, and receptacles;
  - (h) Ground fault circuit interrupters;
  - (i) Amperage and voltage rating of electrical service;
  - (j) Main disconnect(s);
  - (k) Methods or types of wiring;
  - (l) Smoke detectors;
  - (m) Carbon monoxide detectors;
  - (n) Arc fault circuit interrupters.
- (2) The inspector shall inspect all of the visible and readily accessible electrical systems and components.
- (3) The inspector is not required to inspect:
  - (a) Remote control devices;
  - (b) Security alarm systems and components;
  - (c) Low voltage wiring, systems and components, ancillary wiring and systems and components not a part of the primary electrical power distribution system;
  - (d) Generators, photovoltaic solar collectors or battery or electrical storage devices and associated equipment.
- (4) The inspector is not required to:
  - (a) Measure amperage, voltage or impedance;
  - (b) Perform a load calculation;
  - (c) Insert any tool, probe, or device into any electrical component;
  - (d) Determine the accuracy of circuit labeling.

*Rulemaking Authority 468.8325 FS. Law Implemented 468.8323, 468.832(1)(j) FS. History—New 10-22-13.*